



FACILITY INSPECTION CHECKLIST

This checklist highlights the major points of emphasis that the Texas Funeral Service Commission will review and could potentially be cause for non-approval of a facility. This is not an exhaustive list, so continue to maintain regular communication with the Commission during the pre-inspection stages to ensure that all requirements are met prior to the scheduled date of inspection. Check NA in the box if any of these items do not apply to your facility/site.

ITEM	YES	NO	N/A
Appropriate students performing cadaveric dissection or procedures			
Appropriate supervision of students by trained personnel			
Protection of the facility from public access			
Facility secured from access by unauthorized individuals			
Secure entries and exits			
Internal and external monitoring (recommended, not required)			
No public viewing of cadavers during transport into and out of your facility			
Measured air exchange rate of a minimum of 7 complete air exchanges per hour			
Hazardous chemicals properly stored			
Hazardous chemicals measured and within OSHA safety limits			
Source of cadavers (specimens) to be utilized in this facility			
Is the space utilized for any purpose than human cadaver dissection			
Are embalmed and un-embalmed cadavers used concurrently			
What is the disposition of the cadaveric tissue remnants			
Will you do your own cremation			
If so, where and who operates the cremator			
If not, how will the cadavers (specimens) be returned to the originating facility			